

# Energy performance certificate (EPC)

43 ROMER ROAD  
LIVERPOOL  
L6 6DH

Energy rating

C

Valid until: **13 July 2031**

Certificate number: **0300-8872-0122-3099-0393**

Property type

Mid-terrace house

Total floor area

108 square metres

## Rules on letting this property

Properties can be let if they have an energy rating from A to E.

You can read [guidance for landlords on the regulations and exemptions](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance) (<https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance>).

## Energy rating and score

This property's current energy rating is C. It has the potential to be B.

[See how to improve this property's energy efficiency.](#)

Score	Energy rating	Current	Potential
92+	A		
81-91	B		88 B
69-80	C	71 C	
55-68	D		
39-54	E		
21-38	F		
1-20	G		

The graph shows this property's current and potential energy rating.

**Properties get a rating from A (best) to G (worst) and a score.** The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

the average energy rating is D  
the average energy score is 60

## Breakdown of property's energy performance

### Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Solid brick, as built, no insulation (assumed)	Poor
Roof	Pitched, no insulation	Very poor
Roof	Roof room(s), insulated (assumed)	Very good
Window	Fully double glazed	Good
Main heating	Boiler and radiators, mains gas	Good
Main heating control	Programmer, room thermostat and TRVs	Good
Hot water	From main system	Good
Lighting	Low energy lighting in all fixed outlets	Very good
Floor	Suspended, no insulation (assumed)	N/A
Secondary heating	None	N/A

### Primary energy use

The primary energy use for this property per year is 189 kilowatt hours per square metre (kWh/m<sup>2</sup>).

---

## How this affects your energy bills

An average household would need to spend **£792 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £228 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2021** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

### Heating this property

Estimated energy needed in this property is:

- 11,156 kWh per year for heating
- 2,263 kWh per year for hot water

### Saving energy by installing insulation

Energy you could save:

- 1,319 kWh per year from loft insulation
- 2,248 kWh per year from solid wall insulation

### More ways to save energy

Find ways to save energy in your home by visiting [www.gov.uk/improve-energy-efficiency](https://www.gov.uk/improve-energy-efficiency).

## Environmental impact of this property

This property produces 3.6 tonnes of CO<sub>2</sub>

This property's current environmental impact rating is D. It has the potential to be B.

This property's potential production 1.4 tonnes of CO<sub>2</sub>

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO<sub>2</sub>) they produce each year. CO<sub>2</sub> harms the environment.

You could improve this property's CO<sub>2</sub> emissions by making the suggested changes. This will help to protect the environment.

### Carbon emissions

An average household produces 6 tonnes of CO<sub>2</sub>

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

## Changes you could make

Step	Typical installation cost	Typical yearly saving
1. Increase loft insulation to 270 mm	£100 - £350	£57
2. Internal or external wall insulation	£4,000 - £14,000	£97
3. Floor insulation (suspended floor)	£800 - £1,200	£42
4. Solar water heating	£4,000 - £6,000	£32
5. Solar photovoltaic panels	£3,500 - £5,500	£340

## Help paying for energy improvements

You might be able to get a grant from the [Boiler Upgrade Scheme \(https://www.gov.uk/apply-boiler-upgrade-scheme\)](https://www.gov.uk/apply-boiler-upgrade-scheme). This will help you buy a more efficient, low carbon heating system for this property.

---

## Who to contact about this certificate

### Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Jordan Ware
Telephone	07949532756
Email	<a href="mailto:jwarepropertyservices@gmail.com">jwarepropertyservices@gmail.com</a>

### Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Stroma Certification Ltd
Assessor's ID	STRO024509
Telephone	0330 124 9660
Email	<a href="mailto:certification@stroma.com">certification@stroma.com</a>

### About this assessment

Assessor's declaration	No related party
Date of assessment	13 July 2021
Date of certificate	14 July 2021
Type of assessment	<a href="#">RdSAP</a>

---